



TERMINALS SUITABLE FOR 22-16 AWG (0.6mm² - 1.3mm²) FIELD WIRING
 TIGHTENING TORQUE = 0.5Nm (4.5lb-in)

NOTE 1
 A 120 OHM TERMINATION RESISTOR MUST BE FITTED IF IT IS THE FIRST OR LAST DEVICE ON AN RS485 LINK

NOTE 2

AC INPUT	ANTI-SURGE FUSE RATING
110V	6.3A
230V	3.5A

WHEN CURRENT LIMIT IS CONFIGURED BELOW 10A, FUSE APPROPRIATELY

NOTE 3
 FUSE APPROPRIATELY AND AS CLOSE TO THE BATTERY AS POSSIBLE TO PROTECT THE CABLES AND BATTERY

UNITS = NA	AS 02/11/12		DEEP SEA ELECTRONICS PLC HIGHFIELD HOUSE HUNMANBY INDUSTRIAL EST. N. YORKSHIRE, YO14 0PH
	AS 31/10/12		
	AS 24/05/12		
	AS 22/02/12		
TOLERANCE	REVISION	DATE	TITLE
NA	CHK/ADM	24/05/12	TYPICAL CONNECTIONS
	CHK/IFH	09/01/12	9470/9480 BATTERY CHARGER
	DRN/IAS	05/01/12	DWG No. 035-148
			ISS No. 4
			SHEET No. 1/1