



BATTERY NEGATIVE MUST BE GROUNDED

NOTE 1
FUSE APPROPRIATELY AND AS CLOSE TO THE BATTERY CHARGER AS POSSIBLE TO PROTECT THE CABLES

NOTE 2
FUSE APPROPRIATELY AND AS CLOSE TO THE BATTERY AS POSSIBLE TO PROTECT THE CABLES AND BATTERY

UNITS = NA				 DEEP SEA ELECTRONICS HIGHFIELD HOUSE HUNMANBY INDUSTRIAL EST. N. YORKSHIRE, YO14 0PH
TOLERANCE	REVISION	DATE		
NA	CHK.			TYPICAL CONNECTIONS BC1205/BC2405 DWG No. 035-306
	CHK.			
	DRN. IAS	22/07/22		ISS No. 2
				SHEET 1/1