



BATTERY NEGATIVE MUST BE GROUNDING

NOTE 1. THESE GROUND CONNECTIONS MUST BE ON THE ENGINE BLOCK, AND MUST BE TO THE SENSOR BODIES.

UNITS = NA				DSE		DEEP SEA ELECTRONICS PLC HIGHFIELD HOUSE HUNMANBY INDUSTRIAL EST. N. YORKSHIRE, YO14 0PH	
TOLERANCE	REVISION	AS	10/06/16	TITLE		TYPICAL CONNECTIONS	
NA	CHK.			E100			
	CHK.			DWG No.		035-241	
	DRN.	AS	12/08/15	ISS No.		2	
				SHEET		1/1	