



BATTERY NEGATIVE MUST BE GROUND

NOTE 1. THESE GROUND CONNECTIONS MUST BE ON THE ENGINE BLOCK, AND MUST BE TO THE SENSOR BODIES.

NOTE 3. IT IS RECOMMENDED THAT THE GENERATOR AND MAINS SWITCHING DEVICES ARE MECHANICALLY AND ELECTRICALLY INTERLOCKED.

NOTE 2. 120 R TERMINATING RESISTOR MAY BE REQUIRED EXTERNALLY, SEE ENGINE MANUFACTURERS LITERATURE.

NOTE 4. MAINS BREAKER CLOSED OUTPUT SHOULD BE CONFIGURED FOR DE-ENERGISE CLOSE MAINS, AND USE THE NORMALLY CLOSED CONTACTS OF MBCR

UNITS = NA				DSE		DEEP SEA ELECTRONICS PLC HIGHFIELD HOUSE HUNMAYNBY INDUSTRIAL EST. N. YORKSHIRE, YO14 0PH	
		AS 02/02/16		TITLE		TYPICAL CONNECTIONS	
TOLERANCE	REVISION	DATE	4520MKII				
NA	CHK1						
	CHK2						
	DRN.IAS	30/01/15	DWG No.	035-235	ISS No.	2	SHEET 1/1